

# TEST REPORT

No : CT13-44399

## 6. Results of Testing(Inspection)

Test Items	Test Results			Test method
	Early Conc. (CFU/m <sup>3</sup> )	After 3 h Conc (CFU/m <sup>3</sup> )	Reduction rate of bacteria(%)	
Reduction test for Airborne microbes	Air Purifier (AIRVAX 33X2)	5.4 × 10 <sup>3</sup>	< 10	99.8

\* CFU : Colony Forming Unit

\* Test strain : MRSA(*Staphylococcus aureus* subsp. *aureus* ATCC 33591)

\* Chamber size : 8 m<sup>3</sup>

\* Measurement equipment : MAS-100 NT (MERCK, Flow rate : 100 L/min)

\* Test condition : Temperature : (25 ± 1) °C, Humidity : (50 ± 5) % R.H.

\* Sample : Air Purifier(AIRVAX 33X2)

\* Operating time : 3 hours

\* Result concentration : Feller Conversion Table application

\* Client's requirement method : After injecting a constant concentration of target bacteria inside the test chamber and operating the sample for 3 hours, measure the reduction rate of bacteria.