

# IAPMO RESEARCH AND TESTING, INC.

5001 East Philadelphia Street, Ontario, California 91761-2816 – USA • 909-472-4100 • 909-472-4244 • www.iapmort.org



## CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

The most updated information on this Certificate of Listing is available online at [pld.iapmo.org](http://pld.iapmo.org)

Effective Date: April 2018 -Rev. 6/1/2018- Void After: April 2019

Product: Drinking Water Treatment Unit - Aesthetic Effects File No. W-9817

Issued To: Paragon Water Systems, Inc.  
13805 Monroes Business Park  
Tampa, FL 33635

Identification: Each product shall be permanently and legibly marked by means of a permanent plate(s) or label(s) affixed in a readily accessible location to the system. This information shall include the model number, name and address of manufacturer, functional description of the system, maximum working pressure in kPa (psig), maximum operating temperature in degrees C (degrees F), and a statement noting that the system conforms to NSF/ANSI 42 for the specific performance claims as verified and substantiated by test data. Where applicable and appropriate, the information shall also include the model number of replacement components, electrical requirements, and a statement (or its equivalence) for activated carbon systems: "Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system."

Product shall also bear the UPC® certification mark.

Characteristics: Point-of-use and point-of-entry systems intended to reduce substances

  
Chairman, Product Certification Committee

  
CEO, The IAPMO Group

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.





# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

-Rev. 6/1/2018-

Void After: April 2019

Product: Drinking Water Treatment Unit - Aesthetic Effects

File No. W-9817

Issued To: Paragon Water Systems, Inc.

affecting the aesthetic quality of the water or to add chemicals for scale control, or both.

Certification demonstrates that all materials safety and structural integrity (as applicable) requirements have been met.

To be installed in accordance with the manufacturer's installation instructions and the requirements of the latest edition of the Uniform Plumbing Code®.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)

Products are in compliance with the following standard(s):

NSF/ANSI 42-2016



# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

-Rev. 6/1/2018-

Void After: April 2019

Product: Drinking Water Treatment Unit - Aesthetic Effects

File No. W-9817

Issued To: Paragon Water Systems, Inc.

MODELS:

<u>Model Number</u>	<u>Flow Rate (GPM)</u>	<u>Capacity (Gallons)</u>	<u>Replacement Component</u>	<u>Reduction Claims</u>
<b>Product Type: Plumbed-In</b>				
UCSTH2-CP <sup>1</sup>	0.75	389	CP-2	Chloramine, Chlorine, Particulate Class I
UCSTH4-CP <sup>1</sup>	1.25	651	CP-4	Chloramine, Chlorine, Particulate Class I
UCSTH6-CP <sup>1</sup>	1.5	784	CP-6	Chloramine, Chlorine, Particulate Class I
C-FIL-P034800W+CB	0.5	1000	N/A	Chlorine, Taste and Odor
C-FIL-P034761W+ C-FIL-P034764W+CB	0.5	1000	N/A	Chlorine, Taste and Odor
TLSHF138	0.85	389	N/A	Chlorine, Taste and Odor, Chloramine, Particulate Class 1
TLSHF238	1.7	778	N/A	Chlorine, Taste and Odor, Chloramine, Particulate Class 1
DPTL3 <sup>1</sup>	1.0	1000	R-DPTL3-LVL3, R-DPTL3-HFM	Chlorine, Taste and Odor, Particulate Class I
DPTL3A <sup>1</sup>	1.0	778	R-DPTL3-LVL4, R-DPTL3A-HFM	Chloramine, Chlorine, Taste & Odor, Particulate Class I
STH1-FC1PB2	1.5	4750	FC1PB2	Chlorine, Taste and Odor
STH1-FC1PB4	2.0	7900	FC1PB4	Chlorine, Taste and Odor
STH1-FC1PB6	2.5	9500	FC1PB6	Chlorine, Taste and Odor
PF031 <sup>1</sup>	1.0	2500	CBC300	Chlorine, Taste and Odor
PF044 <sup>1</sup>	1.89	4735	CBC500	Chlorine, Taste and Odor



# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

-Rev. 6/1/2018-

Void After: April 2019

Product: Drinking Water Treatment Unit - Aesthetic Effects

File No. W-9817

Issued To: Paragon Water Systems, Inc.

HFM1-FC1PB2	1.5	4750	FC1PB2	Chlorine, Taste and Odor
HFM1-FC1PB4	2.0	7900	FC1PB4	Chlorine, Taste and Odor
HFM1-FC1PB6	2.5	9500	FC1PB6	Chlorine, Taste and Odor
Classic <sup>6</sup>	0.5	25000	N/A	Chlorine, Taste and Odor
G30 <sup>6</sup>	0.5	30000	N/A	Chlorine, Taste and Odor
G6 <sup>7</sup>	0.5	30000	N/A	Chlorine, Taste and Odor, Particulate Class V
F5 <sup>6</sup>	0.5	40000	N/A	Chlorine, Taste and Odor, Particulate Class V
G40 <sup>7</sup>	0.5	40000	N/A	Chlorine, Taste and Odor, Particulate Class V
G40+ <sup>6</sup>	0.5	40000	N/A	Chlorine, Taste and Odor, Particulate Class V
P35 <sup>7</sup>	0.5	35000	N/A	Chlorine, Taste and Odor, Particulate Class V
CLASSIC + GUARDIAN MAX <sup>4</sup>	0.5	25000	N/A	Chlorine, Taste and Odor
G30 + GUARDIAN MAX <sup>4</sup>	0.5	30000	N/A	Chlorine, Taste and Odor
FSH-CCB1PBAL4	1.39	1389	CCB1PBAL4	Chlorine, Taste and Odor, Particulate Class I
FSH-EKFC1PB2	1.50	4750	EKFC1PB2	Chlorine, Taste and Odor
P0703-00001	0.50	750	A0000-0058	Chlorine, Taste and Odor, Particulate Class I
P0703-00002	0.50	1000	A0000-0059	Chlorine, Taste and Odor, Particulate Class I
P0703-00003	0.50	300	A0000-0057	Chlorine, Taste and Odor, Particulate Class I
TLSH238-HFM	0.85	389	TLSHF-CB-R TLSH-HFM-R	Chlorine, Taste and Odor, Chloramine, Particulate Class 1



# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

-Rev. 6/1/2018-

Void After: April 2019

Product: Drinking Water Treatment Unit - Aesthetic Effects

File No. W-9817

Issued To: Paragon Water Systems, Inc.

**Product Type: Component**

C-FIL-P034800W <sup>3</sup>
C-FIL-P034761W <sup>3</sup>
C-FIL-P034764W <sup>3</sup>
P140-00302 <sup>1, 3</sup>
P140-00301 <sup>1, 3</sup>
A140-00304X <sup>1, 3, 4</sup>
FCabCL01 <sup>5</sup>

All products in this listing are certified whether they bear the mark or not.

<sup>1</sup> Product also evaluated and determined to possess weighted average lead content of  $\leq 0.25\%$  and complies with lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

<sup>3</sup> Product is certified for materials safety and structural requirements only.

<sup>4</sup> X equals 1/4 or 3/8 QC

<sup>5</sup> a = diameter: 2.5" or 4.5" and b = length: 10", 20". Products have been tested for and meet the standard requirements for chlorine taste and odor, lead and cyst reduction

<sup>6</sup> Certified colors include black, chrome, red, and white.

<sup>7</sup> Certified colors include black, bronze, chrome, red, and white.